



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2012592  
Permit #: 00885-2023UPG  
Request Rec'd: 08/11/2023  
Amended Date: 08/14/2023 DS  
Approval Date: 08/13/2023 DS  
Permit Expires: 02/13/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Zion Travel Center, Inc. 702 Kentshire Circle Elgin, IL 60124 (None) County Contact: Japneet Khaira 765/881-0511	<b>FACILITY</b> - name and address where tanks are located: Toor's Car & Truck Plaza 43067 N. Hwy. 41 I-94 & Russell Rd. Wadsworth, IL 60083 Lake County Contact: Sam Toor 847/395-5000
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Per failed testing the Regular spill containr will be replaced with a double walled spill container. 8/14/23, the existng overfill prevention drop tube was also replaced.

**Special Contingencies**

**Amendment Reason:**

The overfill preventio dro tube also required replacement.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Daniel Starks