



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

|                            |               |
|----------------------------|---------------|
| <b>FOR OFFICE USE ONLY</b> |               |
| Facility #:                | 4037332       |
| Permit #:                  | 00895-2023UPG |
| Request Rec'd:             | 08/15/2023    |
| Approval Date:             | 08/15/2023 DS |
| Permit Expires:            | 02/15/2024    |

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |   |
|--|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Gilman Landco, LLC<br>2275 Half Day Road, Suite 127<br>Bannockburn, IL 60015<br>Cook County<br>Contact: Gary Meyers 312/282-1060 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Fred's Fuel 'n Food Mobil #1<br>624 US Highway 24 West<br>Gilman, IL 60938<br>Iroquois County<br>Contact: Denise Futrell 815/383-4001 |
|--|---|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2      | Gasoline - Regular | 10,000   | Currently in use | Federal          |

**Tank 2 Equipment**

| Equipment Type          | Permit Equipment                           | Action  |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

**Summary of Work**

Existing electronic leak detector is obsolete. Replacing with a mechanical leak detector.

**Special Contingencies**

|   |   |
|---|---|
| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>                                     |   |
| Seneca Companies, Inc.<br>4140 East 14th Street PO Box 3360<br>Des Moines, IA 50313 | Contact Person: Glen Davis<br>Phone: 515/601-6635<br>Email: jfranklin@senecaco.com<br>Contractor License # IL598 Exp. 2/23/2024 |

Sincerely,

Daniel Starks