

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2001606
Permit #: 00899-2023CAT
Request Rec'd: 08/15/2023
Approval Date:08/15/2023 DS
Permit Expires: 02/15/2024

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Diya Patel, Inc. 501 W. 87th Street Naperville, IL 60565 Will County

Contact: Mike Patel 773/981-1875

FACILITY

- name and address where tanks are located:

Diya Patel, Inc. 501 W. 87th Street Naperville, IL 60565 Du Page County

Contact: Mike Patel 773/981-1875

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	7,600	Currently in use	Federal
2	Gasoline - Regular	7,600	Currently in use	Federal
3	Gasoline - Regular	7,600	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Install cathodic protection on all 3 STPs
Replace all 3 ATG manholes
Replace tank 3 probe cable
Replace tank 2 junction box
Install Self Service signs at dispensers and supply waste drum to owner

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group

2422 Center Street Rockford, IL 61108 Contact Person: Robert Stenstrom

Phone: 815/520-5292

Email: trevorh@rstenstrom.com

Contractor License # IL1890 Exp. 4/12/2024

Sincerely, Daniel J. Starks

Daniel Starks