



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 1022673  
Permit #: 00903-2023UPG  
Request Rec'd: 08/16/2023  
Approval Date: 08/16/2023 DS  
Permit Expires: 02/16/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Commonwealth Edison/Exelon Corporation 3 Lincoln Center - Real Estate & Facilities Oakbrook Terrace, IL 601814260 Du Page County Contact: Michael Grazioli 630/303-2681	<b>FACILITY</b> - name and address where tanks are located: Com Ed Dixon Headquarters 919 S 1st St Dixon, IL 61021 Lee County Contact: Dan Stankoskey 630/341-4054
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	B-20	10,000	Currently in use	Federal
5	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor

### Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown

### Summary of Work

Need to replace diesel dispenser sensor. Upgrade site to positive shut down on entire system as a result.

### Special Contingencies

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Superior Petroleum Marketers, Inc.  
2336 Albright Lane P. O.Box 4648  
Wheaton, IL 601894648

Contact Person: Steve Tuttle  
Phone: 630/588-1198  
Email: tuttle.steve11@gmail.com  
Contractor License # IL2087 Exp. 2/4/2024

Sincerely,



Daniel Starks