



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2036117  
Permit #: 00904-2023ABN  
Request Rec'd: 08/16/2023  
Approval Date: 08/16/2023 DS  
Permit Expires: 02/16/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Village of Lansing 3141 Ridge Road Lansing, IL 60438 Cook County Contact: Deputy Chief Roberts 708/895-7200	<b>FACILITY</b> - name and address where tanks are located: Lansing Police Facility 2710 E. 170th Street Lansing, IL 60438 Cook County Contact: Deputy Chief Roberts 708/895-7190
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
1	10,000	Gasoline - Regular	Inert material mixed with portland cement	

**Explanation of Waiver for Abandonment**

Abandonment required due to location of ATT utility line running directly above the UST tank.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2024

Sincerely,

Daniel Starks