

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 2037493
Permit #: 00898-2023UPG
Request Rec'd: 08/15/2023
Amended Date:08/17/2023 Chi
Approval Date: 08/15/2023
Permit Expires: 02/15/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:

Shabeena Afridi
5726 N. Nagle Ave.
Chicago, IL 60646
Cook County

Contact: Nasir Afridi 630/292-5604

FACILITY
- name and address where tanks are located:

My Mart Citgo
5726 N. Nagle
Chicago, IL 60646
Cook County

Contact: Hamed Khan 773/631-6333

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Other Steel Riser	New
Overfill Prevention Device	East - Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

We are changing the Premium spill bucket, drop tube and its riser by digging down to the tank top We are changing the risers for the probe for the Regular and Premuim tanks

Amendement: For Regular Changing the Spill bucket, drop tube along with riser. Dogdown to tank top is needed Thank you

Innovative Constructions

Special Contingencies

Amendment Reason:

Regular spill bucket also need to be replaced with Double wall spill bucket along with drop tube Thank you Innovative Constructions

PERSON, FIRM OR COMPANY PERFORMING WORK:

Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28

West Chicago, IL 60185

Contact Person: Raju penumatsa Phone: 630/747-3404

Email: iconstructions81@gmail.com

Contractor License # IL002453 Exp. 2/7/2024

Sincerely,

Raul Valdivia