



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1009424
Permit #: 00911-2023UPG
Request Rec'd: 08/16/2023
Approval Date: 08/17/2023 SB
Permit Expires: 02/19/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Air Products & Chemicals, Inc. 1940 Air Products Blvd. Allentown, PA 18106 (None) County Contact: Preston Klingseis 610/481-5909	FACILITY - name and address where tanks are located: Air Products and Chemicals, Inc. 318 N. 30th Road La Salle, IL 613013249 LaSalle County Contact: Don Black 815/224-1577
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	10,000	Currently in use	Federal
3	Diesel Fuel	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New

Summary of Work

We will take off existing dispenser, install new UDC under existing dispenser, install new shear valve and reinstall dispenser

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Bryan Estes
Phone: 309/202-0792
Email: amannino@iome.com
Contractor License # IL1293 Exp. 2/4/2024

Sincerely,



Shelly Bradley

For Office Use Only**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing