



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2023609
Permit #:	00914-2023UPG
Request Rec'd:	08/17/2023
Approval Date:	08/18/2023 DS
Permit Expires:	02/20/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Elk Grove Park District 499 Biesterfield Road Elk Grove Village, IL 60007 Cook County Contact: Ryan Lee 630/532-7527	FACILITY - name and address where tanks are located: Elk Grove Park District 499 Biesterfield Road Elk Grove Village, IL 60007 Cook County Contact: Ryan Lee 847/690-1190
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	2,000	Currently in use	Federal
5	Diesel Fuel	1,000	Currently in use	Federal
6	Diesel Fuel	1,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Removing
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Piping	Other Steel Riser	New
Piping	Ball Valves	New
Piping	Flex Connector Steel	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Piping	Other Steel Riser	New
Piping	Flex Connector Steel	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Piping	Other Steel Riser	New
Piping	Flex Connector Steel	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replace existing tank top sumps

Replace spill buckets and overfill drop tubes

Replace all tank top risers

Replace ball valve and flex connectors inside new tank top sumps

Product piping and vent piping to be cut back just far enough to install new sumps and then ran into new sumps in the same location old pipe were at

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks