



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2023271
Permit #: 00918-2023UPG
Request Rec'd: 08/17/2023
Approval Date: 08/18/2023 DS
Permit Expires: 02/20/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: US Department of Energy 9800 S. Cass Ave. Lemont, IL 60439 Du Page County Contact: Kaushik Joshi 630/252-4226	FACILITY - name and address where tanks are located: Argonne National Laboratory 9700 S. Cass Ave. Argonne, IL 60439 Du Page County Contact: Mark Pfeiffer 630/252-6408
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
62	E85	10,000	Currently in use	Federal

Tank 62 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Dispensers on the Permit

Dispenser	Action
3/4	Sump / Sensors Changing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	Reusing Existing

Summary of Work

Replacing existing UDC at E-85 dispenser
product piping will be cut back just far enough to install new dispenser
New flex connector to be installed
Existing sensor with positive shut down will be re-used

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/878-6354
Email: jasonre@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks