



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2009165
Permit #: 00930-2023UPG
Request Rec'd: 08/21/2023
Approval Date: 08/22/2023 DS
Permit Expires: 02/22/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Majid RE, LLC 9329 Odell Ave. Bridgeview, IL 60455 Cook County Contact: Mohammad Majid 708/785-6254	FACILITY - name and address where tanks are located: K&S CC Hills, Inc. 18259 S. Crawford Ave. Country Club Hills, IL 60478 Cook County Contact: Aiman Hussein 708/623-5598
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Gasoline - Regular	6,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flex Connector Steel	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Flex steel pipe inside Tank STP sump is leaking, replacing with new
Replacing the Spill bucket with double wall and changing the drop tubes in both Regular tanks
Thank you
Innovative Constructions

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185	Contact Person: Raju penumatsa Phone: 630/747-3404 Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2024

Sincerely,

Daniel G. Starks

Daniel Starks