



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2034010
Permit #: 00938-2023UPG
Request Rec'd: 08/18/2023
Approval Date: 08/22/2023
Permit Expires: 02/22/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Ramachandra V. Reddy 1051 Killarney Drive Dyer, IN 45311 Lake County Contact: Ketankumar Soni 708/655-3274 | FACILITY - name and address where tanks are located: BP Amoco 8650 S. Morgan Street Chicago, IL 60620 Cook County Contact: Ahmed Maklani 773/349-5551 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 12 | Gasoline - Premium | 8,000 | Currently in use | Federal |

Tank 12 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--|--|
| Leak Detection - Piping | Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown |

Summary of Work

The Premium STP sump sensor required replacement and Positive shut-down added.

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024 |

Sincerely,

Raul Valdivia