

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services 1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY
Facility # 7-025267
Permit # 00648-2007INS
Request Rec'd 05/09/2007
Amended Date
Approval Date 5/11/2007 JC
Permit Expires 11/11/2007

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
King Steve A 622 Greenwood Ave Duquoin, IL 62832	Fredericks Battery Station 622 Greenwood Ave Duquoin, Perry Co., IL
Contact:	Contact: King Steve A (618) 542-4224

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 6) 150 gallons
- (b) Type of tanks: (TK # 6) (Installing) ACT 100 single wall composite
- (c) Type of piping: (TK # 6) (Installing) Galvanized Steel single wall
- (d) Product to be stored in each tank: (TK # 6) Waste Oil

(e) Type of leak detection being used:

Tank: (TK # 6) - (Installing) Manual tank gauging

Piping: (TK # 6) - (Installing) Gravity feed

(f) Corrosion Protection being used:

Tank: (TK # 6) - (Installing) Composite

Piping: (TK # 6) - (Installing) Gravity feed piping

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

(5) <u>GENERAL REQUIREMENTS:</u>

(6) <u>SPECIAL CONTINGENCIES</u>:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Phone:

Contractor Registration # Exp.

Sincerely,

Janu & Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)