

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 7-025301
Permit # 00647-2007INS
Request Rec'd 05/09/2007
Amended Date
Approval Date 5/10/2007 JC
Permit Expires 11/10/2007

## Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1)	<b>OWNER</b>	OF	<b>TANKS</b>	- Corporation	, partnership	or other
	husiness en	tity:				

business entity:

Bugaieski Oil Company

c/o Diedre Nolan, Executrix of the Estate, 11410 Fox Hunter

Road

Mulkeytown, IL 62860

Contact: Diedre Nolan (618) 439-9427

(2) FACILITY - name and address where tanks are located:

Auto Ser Station Junction Rt 184 & Rt 14 Mulkeytown, Franklin Co., IL

Contact: Bugaieski Tony (618) 724-2418

## (3) <u>INSTALLATION OF TANKS:</u>

(a) Number and size of tanks being installed: (TK # 4) - 150 gallons

(b) Type of tanks: (TK # 4) - (Installing) ACT 100 single wall composite

(c) Type of piping: (TK # 4) - (Installing) Galvanized Steel single wall

(d) Product to be stored in each tank: (TK # 4) - Waste Oil

(e) Type of leak detection being used:

Tank: (TK # 4) - (Installing) Manual tank gauging

Piping: (TK # 4) - (Installing) Gravity feed

(f) Corrosion Protection being used:

*Tank:* (TK # 4) - (Installing) Composite

Piping: (TK # 4) - (Installing) Gravity feed piping

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) **SPECIAL CONTINGENCIES**:

(7	()	PERSON.	FIRM (	<u>OR COMPA</u>	<u>NY PERFO</u>	DRMING	<u>WORK</u>

Contact Person:

Phone:

Contractor Registration # Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department -

Office Coordinator -

Division File

(Rev. - 1/98)

James of Coffey