



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 4-016258
Permit # 00029-2007UPG
Request Rec'd 12/18/2006
Amended Date 05/09/2007
Approval Date 1/5/2007 JC
Permit Expires 7/5/2007

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

Table with 2 columns: (1) OWNER OF TANKS - Corporation, partnership, or other business entity; (2) FACILITY - name and address where tanks are located. Includes contact information for Green Andrew H and Mahoney T.

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 14, 15, 16) - 4,000 gallons, (TK # 17) - 8,000 gallons, (TK # 18, 19, 20, 21, 22, 23) - 30,000 gallons, (TK # 25) - 650 gallons, (TK # 26, 27, 28) - 1,000 gallons
(b) Type of tanks:
(c) Type of piping: (TK # 15, 16, 17) - (Installing) Ameron double wall fiberglass
(d) Product to be stored in each tank: (TK # 14, 25, 26) - Diesel Fuel, (TK # 15, 16, 17) - Fuel Oil, (TK # 18, 19, 20, 21, 22, 23) - Heating Oil, (TK # 27, 28) - Gasoline
(e) Type of leak detection being used:
Tank: (TK # 14, 15, 16, 17, 25, 26, 27, 28) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge with CSLD, (TK # 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 25, 26, 27, 28) - (Installing) Veeder Root TLS 350 Plus Interstitial tank sensor
Piping: (TK # 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 25, 26, 27, 28) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors (TK # 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 25, 26, 27, 28) - Interstitial sensors will be installed at all submersible sumps.
(f) Corrosion Protection being used:
Tank:
Piping: (TK # 15, 16, 17) - (Installing) Fiberglass
(g) Spill containment devices:
(h) Overfill prevention devices:
(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Dave Long, Phone: Contractor Registration # Exp.

Sincerely,

Handwritten signature of James J. Coffey

Jim Coffey

