



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
 Facility # 1-043398
 Permit # 01676-2006INS
 Request Rec'd 11/08/2006
Amended Date 05/03/2007
 Approval Date 11/8/2006 JC
 Permit Expires 11/8/2007

Extended/Amended

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Vista Marketing Group Box 6206 Rockford, IL 61125-6206</p> <p>Contact: Chip Williams (815) 964-3920</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Riverside Shell Riverside & Applewood Loves Park, Winnebago Co., IL</p> <p>Contact: Chip Williams (815) 964-3920</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed:* (TK # 1, 2, 3, 4) - 12,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3, 4) - (Installing) Single wall fiberglass
- (c) *Type of piping:* (TK # 1, 2, 3, 4) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:** (TK # 1, 2, 3, 4) - (Installing) Incon TS-550 automatic tank gauge
 - Piping:** (TK # 1, 2, 3, 4) - (Installing) Incon TSL5 500 electronic line leak detector
- (f) *Corrosion Protection being used:*
 - Tank:** (TK # 1, 2, 3, 4) - (Installing) Fiberglass
 - Piping:** (TK # 1, 2, 3, 4) - (Installing) Fiberglass
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Contact Person: Nate Meyer Phone: Contractor Registration # Exp.</p>
--

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)