



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 3-022691
Permit # 00515-2007REM
Request Rec'd 04/12/2007
Amended Date 04/24/2007
Approval Date 4/16/2007 DS
Permit Expires 10/16/2007

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Midwest Generation, L.L.C. 440 S. LaSalle Street, One Financial Place Suite 3500 Chicago, IL 60605 Contact: Jeff Bard (312) 583-6105	(2) FACILITY - name and address where tanks are located: Powerton Generating Station 13082 E. Manito Road Pekin, Tazewell Co., IL Contact: Michael T Reed (309) 477-5289
--	---

(3) REMOVAL OF TANKS:

- (a) **Number and size of tanks being removed:** (TK # 475, 477) - 3,800 gallons, (TK # 478) - 7,700 gallons, (TK # 479) - 19,000 gallons, (TK # 480, 481) - 6,000 gallons
 - (b) **Product stored in each tank:** (TK # 475, 477, 478, 480, 481) - Lubricating Oil, (TK # 479) - Fuel Oil
 - (c) **Reason of tanks being removed:**
 - (d) **If tank(s) is leaking, indicate IEMA incident number:** 20070428
 - (e) **Date each tank was last used:** (TK # 475, 477, 478, 479, 480, 481) - 01/01/1975
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Amendment request to add tanks #480 and #481 received 04/20/07. Site has multiple incident #'s: H20070428, H20070441, H20070482.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Brandenburg Industrial Service Co. 2625 South Loomis Street	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)