

### Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Kroger Company 5960 Castleway West Dr. Indianapolis, IN 46250	Kroger Fuel Center #J918 9219 N. Lindbergh Dr. Peoria, Peoria Co., IL
Contact: Nick Bondar (317) 579-8281	Contact:

#### (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (1) compartment tank consisting of: (TK # 1) 8,000 gallons, (TK # 2) 20,000 gallons
- (b) Type of tanks: (TK # 1, 2) (Installing) XERXES double wall fiberglass brine filled
- (c) Type of piping: (TK # 1, 2) (Installing) A.P.T. Poly Tech P150SC double wall flexible product piping, (TK # 1, 2) (Installing) A.P.T. Poly Tech DCT-400 secondary chase piping.
- (d) Product to be stored in each tank: (TK # 1, 2) Gasoline
- (e) Type of leak detection being used:

*Tank:* (TK # 1, 2) - (Installing) Veeder Root TLS350 automatic tank gauge probes for inventory purposes only, (TK # 1, 2) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor for tank leak detection.

*Piping:* (TK # 1, 2) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all dispenser sumps and all submersible sumps, (TK # 1, 2) - (Installing) Veeder Root TLS350 electronic line leak detector

#### (f) Corrosion Protection being used:

Tank: (TK # 1, 2) - (Installing) Fiberglass

Piping: (TK # 1, 2) - (Installing) Fiberglass secondary containment, (TK # 1, 2) - (Installing) Non-corrosive flexible

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

(5) <u>GENERAL REQUIREMENTS:</u> There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons.

# (6) <u>SPECIAL CONTINGENCIES</u>:

## (7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Phone:

Contractor Registration # Exp.

Sincerely,

Jame J affey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)