



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-026112  
Permit # 00506-2007ENT  
Request Rec'd 04/13/2007  
Amended Date  
Approval Date 4/16/2007 JC  
Permit Expires 10/16/2007

**Permit for ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Pacific Petroleum 1306 W. Hainesville Rd. Round Lake Beach, IL 60073  Contact: John Kim (847) 546-4161	<b>(2) FACILITY</b> - name and address where tanks are located:  Hainesville Phillips 66 1306 W. Hainesville Rd Round Lake Beach, Lake Co., IL  Contact: John Kim (847) 546-4161
---	--

**(3) ENTRY OF TANKS:**

(a) *Number and size of tanks being entered:* (TK # 1, 2) - 5,000 gallons, (TK # 3, 4) - 6,000 gallons

(b) *Type of tanks:*

(c) *Product stored in each tank:* (TK # 1, 2, 3, 4) - Gasoline See contingencies

(d) *Reason for tanks being entered:* See contingencies

(e) *Manway accessible at grade:* See contingencies

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Metro will saw cut, break out, and excavate to the top of the tanks (ENT permit was required by Bill Alderson to do this). Armor Shield will be doing the lining inspection of the tanks (#00455-2007LIN).

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Phone:  Contractor Registration #    Exp.
---

Sincerely,



cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)