



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 6-007673  
Permit # 00490-2007LIN  
Request Rec'd 04/10/2007  
Amended Date  
Approval Date 4/12/2007 JC  
Permit Expires 10/12/2007

**Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Moto Mart, Inc. 721 W. Main Street, P.O. Box 122 Belleville, IL 62222-0122  Contact: Joseph Hooten (618) 233-6756	<b>(2) FACILITY</b> - name and address where tanks are located:  Chester Moto Mart 435 West Holmes Street, Highway 3 Chester, Randolph Co., IL  Contact: Joe Hooten (618) 826-4223
--	--

**(3) INSPECTION OF INTERIOR LINING OF TANKS:**

- (a) *Number and size of tanks being inspected:* (TK # 1) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Product stored in each tank:* (TK # 1) - Gasoline
- (d) *Manway accessible at grade:* contractor indicates an existing manway on this permit application

**(4) Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.**

**(5) The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(6) SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Note to inspector and for future reference: There is no way to definitively determine what the tank I.D. #'s are for this facility, relative to what grade of fuel is in the tanks, and relative to their positioning in the tank field. Contradictions have been occurring for years in this facility's file history via permits, inspector logs, site plans, etc. According to our records, the "west" tank was lined 07/16/92 (permit #5085-92REL), and the "other two" tanks were lined "sometime" in 1995 or 1996 (permit #1617-95REL). One tank was relined in 2002 (permit #00876-2002REL). Two tanks were inspected 08/15/05 (#00370-2005LIN). At this point in time this office will deem the northwestern most tank as tank #1, the center tank as #2 and the easternmost tank will be #3.

<b><u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>  Superior Equipment Co Inc 3283 Ivanhoe Ave St. Louis, MO 63139	Contact Person: Greg Spiros Phone:  Contractor Registration #    Exp.
--	--

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)