



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 4-017239  
Permit # 01116-2012UPG  
Request Rec'd 10/19/2012  
Amended Date  
Approval Date 10/19/2012 JC  
Permit Expires 4/19/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Maldi 10, Inc. 605 W. Eldorado St. Decatur, IL 62522 Contact: Aswin Patel	<b>(2) FACILITY</b> - name and address where tanks are located: Marathon 605 W. Eldorado Decatur, Macon Co., IL Contact: Aswin Patel (217) 422-2580
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 10) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 10) - (Installing) Submersible Sump containment FRP, (TK # 10) - (Installing) Flex Connector Steel at the submersible sump only, (TK # 10) - (Installing) partial Fiberglass Single Wall Piping and associated fitting(s) at the submersible sump area only. This work will accommodate, and enhance the repair of an existing leaking fitting in the localized area of the submersible pump.
- (d) *Product to be stored in each tank:* (TK # 10) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Oreana, IL 62554	Contact Person: Chuck Hoenig Phone: (217) 468-2393  Contractor Registration # Exp.
---	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)