



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1033319
Permit #: 00942-2023UPG
Request Rec'd: 08/22/2023
Approval Date: 08/23/2023 DS
Permit Expires: 02/23/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: TSA Enterprises, Inc. 320 Holiday Drive Somonauk, IL 60552 LaSalle County Contact: Tom Putz 815/498-2947	FACILITY - name and address where tanks are located: Lake Holiday Marina 320 Holiday Drive Somonauk, IL 60552 De Kalb County Contact: Parker Tazelaar 815/498-2947
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	6,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	West - Single Wall Transition Sump	New
↳ Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	West - Single Wall Transition Sump	New
↳ Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New

Summary of Work

Installing an APT transition sump at mid point of existing Environ product line where (2) lines were nicked during a recent driveway repair. The APT transition sump will contain ball valves 1.5" and a Veeder Root positive shut off non discriminating sump sensor. Lines to be precision tested, sump hydro tested prior to final inspection. (1) Premium line, and (1) RUL line will be cut and then spliced in the transition sump. Approximately 1' of pipe will be removed from each line.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Howard Lee & Sons Inc. 4093 Perryville Road PO Box 446 Cherry Valley, IL 61016	Contact Person: Vicky Buhl Phone: 815/298-3767 Email: patricko@hleeasons.com Contractor License # IL456 Exp. 3/20/2024

Sincerely,

Daniel G. Starks

Daniel Starks