



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2009165  
Permit #: 00930-2023UPG  
Request Rec'd: 08/21/2023  
Amended Date: 08/23/2023 DS  
Approval Date: 08/22/2023 DS  
Permit Expires: 02/22/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Majid RE, LLC 9329 Odell Ave. Bridgeview, IL 60455 Cook County Contact: Mohammad Majid 708/785-6254	<b>FACILITY</b> - name and address where tanks are located: K&S CC Hills, Inc. 18259 S. Crawford Ave. Country Club Hills, IL 60478 Cook County Contact: Aiman Hussein 708/623-5598
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Gasoline - Regular	6,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flex Connector Steel	New

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Flex steel pipe inside Tank STP sump is leaking, replacing with new  
Replacing the Spill bucket with double wall and changing the drop tubes in both Regular tanks  
Amendment : Product pipe double wall fiberglass piping need to be cut and attach to new Stell fex connector pipe for the product (FOR tank 3)  
Thank you  
Innovative Constructions

**Special Contingencies**

**Amendment Reason:**

Product pipe need to be cut to change the Fex steel pipe for tank 3

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Innovative Constructions Technology LLC  
245 W Roosevelt Rd Building 4, Unit 28  
West Chicago, IL 60185

Contact Person: Raju penumatsa  
Phone: 630/747-3404  
Email: iconstructions81@gmail.com  
Contractor License # IL002453 Exp. 2/7/2024

Sincerely,



---

Daniel Starks