



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

**Permit for Emergency Repair Request on 8/18/2023
Revised**

FOR OFFICE USE ONLY

Facility #: 2006664
Permit #: 00919-2023UPG
Request Rec'd: 08/18/2023
Approval Date: 08/18/2023 DS
Extension Date: 08/24/2023
Permit Expires: 08/29/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 380 South Elgin, LLC 1983 Route 52 Suite 1A Hopewell Junction, NY 12533 (None) County Contact: Patty Garcia 845/392-3452	FACILITY - name and address where tanks are located: 380 South Elgin, LLC 380 N. La Fox Street South Elgin, IL 60177 Kane County Contact: Ibrima Sallah 347/499-3835
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Premium	8,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall Environ Geo Flex	Replacing - Piping - Flexible Double Wall Environ Geo Flex

Summary of Work

The Environ, flexible piping female connector was replaced on the premium line in dispenser sump #5/6.

Special Contingencies

Revision Reason:

The Environ, flexible piping female connector was replaced on the dispenser sump **#7/8**.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Daniel Starks