



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2024913
Permit #: 00952-2023UPG
Request Rec'd: 08/25/2023
Approval Date: 08/25/2023 DS
Permit Expires: 02/27/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: First Student, Inc. 600 Vine Street, Suite 1400 Cincinnati, OH 45202 Hamilton County Contact: Susan Kirkpatrick 513/419-8639	FACILITY - name and address where tanks are located: Illinois Central School Bus, LLC 3625 W. Washington Street Park City, IL 60085 Lake County Contact: Matt Finn 847/387-9966
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	12,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS - 4i	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1001 with SCALD
Leak Detection - Tank	Hydrostatic Reservoir Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors

Summary of Work

REPLACING EXISTING ATG WITH NEW VEEDER ROOT TLS4i ATG WITH HYDROSTATIC INTERSTIAL TANK SENSOR FOR BRINE FILLED DW UST

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Petroleum Technologies Equipment, Inc. 8447 West 44th Place Lyons, IL 60534	Contact Person: Thomas Doherty Phone: 708/243-1108 Email: tjdpte@aol.com Contractor License # IL2051 Exp. 1/17/2024

Sincerely,

Daniel Starks