



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Replacement of 00192-2023UPG

FOR OFFICE USE ONLY

Facility #: 2017859
Permit #: 00959-2023UPG
Request Rec'd: 08/28/2023
Approval Date: 08/28/2023 DS
Permit Expires: 02/28/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: South Suburban Hospital 17800 South Kedzie Avenue Hazel Crest, IL 60429 Cook County Contact: George Nelson 708/213-0020	FACILITY - name and address where tanks are located: South Suburban Hospital 17800 S. Kedzie Avenue Hazel Crest, IL 60429 Cook County Contact: John Lee 708/213-0020
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal
2	Diesel Fuel	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel i Site
Leak Detection - Piping	Non-Discriminating Sump Sensor in Single Wall Transition Sump	Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel i Site

Summary of Work

Installing new Veeder Root TLS 4B with internal probes for tank leak detection and sump sensors for piping leak detection for their existing American suction system

Special Contingencies

Replacement Reason:

Did not schedule final prior to permit expiring

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone:
Email:
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks