



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY

Facility #: 2012960
Permit #: 00371-2023REM
Request Rec'd: 04/10/2023
Approval Date: 04/10/2023 DS
Extension Date: 08/30/2023
Permit Expires: 04/11/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the removal at:
<https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710	FACILITY - name and address where tanks are located: Fairfield #109 1115 Fairfield Rd. Round Lake Beach, IL 60073 Lake County Contact: Tiffany Nielsen 847/546-7290
--	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	6,000	Diesel Fuel	
2	6,000	Gasoline - Premium	
3	12,000	Gasoline - Regular	

Summary of Work

Remove all associated product & vent piping prior to installing new piping under separate permit.

Special Contingencies

Remove all associated product & vent piping prior to installing new piping under separate permit.

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: Email: Contractor License # IL881 Exp. 3/8/2025

Sincerely,



Daniel Starks