



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2011079
Permit #: 00973-2023UPG
Request Rec'd: 08/30/2023
Approval Date: 08/30/2023 DS
Permit Expires: 02/29/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Carlson Oil Company, Inc. 307 Franklin Street Newark, IL 60541 Kendall County Contact: Steve Carlson 815/496-2387	FACILITY - name and address where tanks are located: Carlson Oil 303 Rt. 71 Newark, IL 60541 Kendall County Contact: Steve Carlson 815/496-2387
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Premium	8,000	Currently in use	Federal
7	Diesel Fuel	4,000	Currently in use	Federal
9	Gasoline - Regular	20,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket Insert

Summary of Work

Removing 3 Single Wall spill containments and installing 3 new Double Wall EBW Defender, 5 gallon grade level Spill containments. (705-555-12CI)

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: 815/265-7364 Email: pemcogilman@sbcglobal.net Contractor License # IL1224 Exp. 2/26/2024

Sincerely,

Daniel G. Starks

Daniel Starks