



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1038087
Permit #: 00981-2023UPG
Request Rec'd: 08/31/2023
Approval Date: 08/31/2023 DS
Permit Expires: 02/29/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bowen Oil Company 1801 High Street Orangeville, IL 61060 Stephenson County Contact: Wes Bowen 815/789-4248	FACILITY - name and address where tanks are located: Winslow BOCO 221 Carver Street Winslow, IL 61089 Stephenson County Contact: Wes (Chip) Bowen 815/789-4248
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal
3	Gasoline - Premium	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall Transition Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing the existing tank containment sumps and submersible pumps.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 815/209-6640
Email: natem@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks