



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 7001927
Permit #: 00986-2023UPG
Request Rec'd: 09/01/2023
Approval Date: 09/02/2023 DS
Permit Expires: 03/04/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Valerie D. Millis, LLC 90 Old Golconda Rd. Golconda, IL 62938 Pope County Contact: ValerieD.Millis 618/841-5064	FACILITY - name and address where tanks are located: Golconda Gas N Go 120 North Adams Street Golconda, IL 62938 Pope County Contact: Larry W. Millis 618/841-5064
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Gasoline - Regular	10,000	Currently in use	Federal
11	Gasoline - Premium	4,000	Currently in use	Federal

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 2001with SCALD

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 2001with SCALD

Summary of Work

Remove the existing Incon ATG . Install new Veeder Root in-tank probes on tanks 10 & 11 and connect to the existing TLS-350 Plus ATG. The tank interstitial sensors are already on the Existing Veeder Root TLS-350 Plus system. All probes and sensors will now be on the TLS-350 Plus system and the Incon system will be removed.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/267-1231 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2024

Sincerely,

Daniel G. Starks

Daniel Starks