



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1038087
Permit #: 00990-2023REM
Request Rec'd: 09/01/2023
Approval Date: 09/02/2023 DS
Permit Expires: 03/04/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the removal at:
<https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bowen Oil Company 1801 High Street Orangeville, IL 61060 Stephenson County Contact: Wes Bowen 815/789-4248	FACILITY - name and address where tanks are located: Winslow BOCO 221 Carver Street Winslow, IL 61089 Stephenson County Contact: Wes (Chip) Bowen 815/789-4248
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	10,000	Diesel Fuel	
2	8,000	Gasoline - Regular	
3	4,000	Gasoline - Premium	

Summary of Work

Removing existing flex product piping for all products.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: natem@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2024

Sincerely,

Daniel Starks