



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**Permit for Emergency Repair Request on 9/1/2023**

**FOR OFFICE USE ONLY**

Facility #: 4032562  
Permit #: 00996-2023UPG  
Request Rec'd: 09/05/2023  
Approval Date: 09/05/2023 DS  
Permit Expires: 09/18/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Casey's General Store #1764 911 Morrissey Drive Bloomington, IL 61701 McLean County Contact: Jill Reams-Widder 515/965-6238
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel

**Summary of Work**

Installing Flexing Stainless Steel FireFlex 2" flex connector to replace leaking flex. All fuels have been contained and returned to the UST. Repair was tested with nitrogen and a precision test.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2024

Sincerely,

Daniel Starks