



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 4047639
Permit #: 00999-2023ABN
Request Rec'd: 09/05/2023
Approval Date: 09/05/2023 DS
Permit Expires: 03/05/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: KC Home Solutions LLC PO Box 255 Philo, IL 61864 Contact: Felipe Contreras 217/979-0764	FACILITY - name and address where tanks are located: Lincoln Green Residence 715 W. Michigan Ave. Urbana, IL 61801 Champaign County Contact: Dave Holzweiss 773/789-9830
--	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
1	2,500	Heating Oil	Inert material mixed with portland cement	Approx. 18" of black oily liquid in tank

Explanation of Waiver for Abandonment

Please see attahed drawings and pictures of the details of this tank

Location of Tanks Being Abandoned

Tank is located in close proximity to the foundation of the building and also has a sewer line crossing over it.

Location of Piping Being Abandoned

No piping mentioned in application

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/202-0792 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2024

Sincerely,

Daniel Starks