



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY

Facility #: 2006920
Permit #: 00651-2023UPG
Request Rec'd: 06/13/2023
Approval Date: 06/15/2023 DS
Extension Date: 09/07/2023
Permit Expires: 12/15/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Hickory Hills Food Mart 9459 S. Roberts Road Hickory Hills, IL 60457 Cook County Contact: Abdul Basit 708/598-5353 | FACILITY - name and address where tanks are located: Hickory Hills Food Mart 9459 S. Roberts Rd. Hickory Hills, IL 60457 Cook County Contact: Syed Moinuddin 708/598-5353 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Premium | 10,000 | Currently in use | Federal |
| 3 | E85 | 8,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping | Fiberglass Single Wall Piping A.O. Smith | Replacing - Piping - Fiberglass Single Wall Piping |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |
| Piping | Single Wall STP/Tanktop Sump | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|--------|
| 5/6 | New |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Dispenser | Single Wall UDC Sump | New |

Summary of Work

INSTALLING 1 DISPNSER SUMP UNDER DISP 7/8 BECUSE PIPING WILL BE BROKEN TO ALLOW FOR COMPTABLE SHEAR VALVE FOR E85.

INSTALLING 1 STP SUMP BECAUSE PIPING WILL BE BROKEN TO INSTALL E-85 COMPATABLE STP

INSTALLING E85 COMPATABLE DROP TUBE AND SPILL BUCKET

Special Contingencies**Revision Reason:**


Changed equipment for contractor as an amendment wasn't possible due to it being too far along in the permit process

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
1058 National Parkway
Schaumburg, IL 601734519

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2025

Sincerely,



Daniel Starks

For Office Use Only**Tank 3 Equipment**

| Equipment Type | Permit Equipment | Action |
|----------------|--------------------------------|----------|
| Piping | Not Installed STP/Tanktop Sump | Removing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------------|--------|
| Dispenser | Not Installed UDC Sump | Review |