



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 1017061
Permit #: 01027-2023UPG
Request Rec'd: 09/11/2023
Amended Date: 09/12/2023 DS
Approval Date: 09/11/2023 DS
Permit Expires: 03/12/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Hickey's Corner Store, LLC 4201 Rt. 38 East Malta, IL 60150 De Kalb County Contact: Larry Hickey, Jr. 815/756-1724	FACILITY - name and address where tanks are located: Hickey's Corner Store, LLC 4201 Route 38 E. Malta, IL 60150 De Kalb County Contact: Larry Hickey 815/825-2724
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	New

Dispensers on the Permit

Dispenser	Action
7/8	Replacing - 7/8

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New

Summary of Work

Middle RUL tank has an existing future piping chase that was installed during original site construction.
Disconnect submersible from current piping run
Pull new double wall APT pipe through the empty future chase and connect to dispenser 7/8
Reuse existing UDC and sensor
Tank will be converted from RUL to DSL and be sold with new dispenser at 7/8 island

Special Contingencies

Amendment Reason:


Piping to dispenser 7/8, NOT 5/6 Replacing dispenser 7/8, NOT 5/6

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 815/520-5292
Email: trevorh@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks