



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047647
Permit #: 01044-2023REM
Request Rec'd: 09/13/2023
Approval Date: 09/13/2023
Permit Expires: 03/13/2024

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the removal at:
<https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Northwest Side Housing Center 5233 W Diversey Ave. Chicago, IL 60639 Contact: James Rudyk 773/283-3888	FACILITY - name and address where tanks are located: Northwest Side Housing Center 5233 W Diversey Ave. Chicago, IL 60639 Cook County Contact: James Rudyk 773/283-3888
---	--

Tanks on the Permit

Tank #	Capacity	Product	Last Used Date
1	Unknown	Unknown	12/31/1973

Summary of Work

Removal of tank and any associated lines. Tank was encountered during excavation at construction site. Size and contents unknown. Tank is 48" diameter.

Special Contingencies

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2024

Sincerely,

Raul Valdivia