



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 6006767  
Permit #: 00756-2023CAT  
Request Rec'd: 07/07/2023  
Amended Date: 09/14/2023 DS  
Approval Date: 07/09/2023 DS  
Permit Expires: 01/09/2024

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Trentman Holding Company 7151 Hwy. 15 St. Libory, IL 62282 St. Clair County Contact: Casey Trentman 618/444-2526	<b>FACILITY</b> - name and address where tanks are located: Roger's Service & Towing LLC 7151 Hwy 15 St. Libory, IL 62282 St. Clair County Contact: Casey Trentman 618/444-2526
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	10,000	Currently in use	Federal
7	Gasoline - Premium	10,000	Currently in use	Federal
8	Diesel Fuel	10,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	North - Sacrificial Anode Flex Connector	New

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	North - Sacrificial Anode Flex Connector	New

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	North - Sacrificial Anode Flex Connector	New
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Amendment Reason:**

Remove the concrete that is around the dispensers flexible connectors. Install two 20 pound high potential magnesium anodes on the diesel tank at 10' spacing, 1' below tank bottom, through a mini test station and bonding to the tank top. Install two 5-pound high potential magnesium anodes under each dispenser on the flexible connectors (2). Remove the concrete that is around the dispensers flexible connectors. Install two 20 pound high potential magnesium anodes on the diesel tank at 10' spacing, 1' below tank bottom, through a mini test station and bonding to the tank top. Install two 5-pound high potential magnesium anodes under each dispenser on the flexible connectors (2).

**Summary of Work**

PIPING CORROSION PROTECTION SECTION F. INSTALL CORROSION PROTECTION AT THE STPS TO PROTECT EXPOSED FLEX CONNECTORS AND OTHER METAL PORTIONS OF PRODUCT PIPING TANKS 7 & 8. SACRIFICIAL SYSTEM FAILED TEST TANKS 6 & 7. BROKEN CATHODIC PROTECTION WIRING UNDER DISPENSER 1 & 2 NEED REPAIRED AND RETESTED. SAYS WATER COVERS BOOTS NEEDS ANODES

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 210/887-0309 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 2/23/2024

Sincerely,



Daniel Starks