



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2016246
Permit #: 01052-2023UPG
Request Rec'd: 09/14/2023
Approval Date: 09/14/2023 DS
Permit Expires: 03/14/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Chackochan Kizhakkekuttu 1600 S. Oak Park Avenue Berwyn, IL 60402 Cook County Contact: Chackochan Kizhakkekuttu 773/419-4421	FACILITY - name and address where tanks are located: Mariam Chacko, Inc. d/b/a Berwyn BP 1600 S. Oak Park Avenue Berwyn, IL 60402 Cook County Contact: Vincent Varghese 708/484-3035
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	12,000	Currently in use	Federal
8	Gasoline - Premium	10,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Summary of Work

Replace probe risers that are rotting away on both tanks.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks