



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2023096
Permit #: 01053-2023UPG
Request Rec'd: 09/14/2023
Approval Date: 09/14/2023 DS
Permit Expires: 03/14/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: 1990 Mannheim Real Estate, Inc. 1990 Mannheim Road Des Plaines, IL 60018 (None) County Contact: Abraham George 773/216-5917 | FACILITY - name and address where tanks are located: Abraham Gasmart 1990 Mannheim Road Des Plaines, IL 60018 Cook County Contact: Idiculla Joseph 773/216-5917 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 6 | Gasoline - Premium | 12,000 | Currently in use | Federal |
| 7 | Diesel Fuel | 12,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Summary of Work

Removing WPLLD from Regular, Premium and Diesel lines. Installing new red jacket mechanical leak detectors.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Big Daddy Pump & Compliance
301 Main St Unit 105
Antioch, IL 60073

Contact Person: Billy Umphrey
Phone: 352/901-4467
Email: bigdaddypumpco@gmail.com
Contractor License # IL002457 Exp. 12/2/2024

Sincerely,



Daniel Starks