



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6007351
Permit #: 01057-2023UPG
Request Rec'd: 09/15/2023
Approval Date: 09/16/2023 DS
Permit Expires: 03/19/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Sasak Corporation 8711 St. Charles Rock Road St. John, MO 63114 (None) County Contact: Ankit Patel 314/426-3115 | FACILITY - name and address where tanks are located: Route 3 Liquor and Food Mart 3233 West Chain of Rocks Road Granite City, IL 62040 Madison County Contact: Robert E Busse 618/931-0789 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 8 | Gasoline - Regular | 20,000 | Currently in use | Federal |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Non-Discriminating Sump Sensor | Reusing Existing |

Summary of Work

Replacing the existing single wall STP sump with a fiberglass single wall sump. The existing leak detection, sump sensor and STP pump will be reused. We will install new ball valve, flex connector and single wall steel piping inside the sump.

Special Contingencies

| | |
|--|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043 | Contact Person: Terry Smith Phone: 314/797-0468 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2024 |

Sincerely,

Daniel Starks