



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2038856  
Permit #: 01072-2023UPG  
Request Rec'd: 09/19/2023  
Approval Date: 09/20/2023 DS  
Permit Expires: 03/20/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Swift Transportation Company, Inc. 2200 South 75th Avenue Phoenix, AZ 85043 (None) County Contact: Joseph Manley 602/907-3473	<b>FACILITY</b> - name and address where tanks are located: Swift Transportation Company, Inc. 1215 Boudreau Road Manteno, IL 60950 Kankakee County Contact: Steve Brouwer 602/907-3473
---	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	15,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P175SC	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech P175SC

**Summary of Work**

Replacing existing piping with XP175-SC piping.

**Special Contingencies**

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**NOTES: Submersible and dispenser sumps must be installed if not already existing and sensors must be in all with positive shut-down**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: 217/822-8628 Email: cmoore52@frontier.com Contractor License # IL1224 Exp. 2/26/2024

Sincerely,

Daniel Starks