

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 9/13/2023

FOR OFFICE USE ONLY

Facility #: 2009003 Permit #: 01076-2023UPG Request Rec'd: 09/20/2023 Approval Date: 09/20/2023 Permit Expires:10/03/2023

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Parkview Services, Inc. 6700 S. Jeffrey Chicago, IL 60649 Cook County

Contact: Jomon Thomas 630/877-8186

FACILITY

- name and address where tanks are located:

Citac

6700 S. Jeffery Blvd. Chicago, IL 60649 Cook County

Contact: Jemon Thomas 630/877-8186

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Summary of Work

A test company reported two regular pump sumps contain fuel. B&K Equipment technician discovered flex connector leaks in each sump. The failed flexes will be replaced with Hose Master, Fire Shield flex connectors.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Raul Valdivia