



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	1043362
Permit #:	01077-2023UPG
Request Rec'd:	08/02/2023
Approval Date:	09/20/2023 DS
Permit Expires:	03/20/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Monroe Center Oasis, Inc. 5534 N. Limestone Rd. Monroe Center, IL 61052 Ogle County Contact: Andy Lazar 815/393-3600</p>	<p>FACILITY - name and address where tanks are located: Monroe Center Oasis 5534 N. Limestone Rd. Monroe Center, IL 61052 Ogle County Contact: Andy Lazar 815/393-3600</p>
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	Diesel Fuel	12,000	Currently in use	Federal
3	B-11	8,000	Currently in use	Federal
4	Gasoline - Premium	8,000	Currently in use	Federal
5	Gasoline - Non Ethanol	6,000	Currently in use	Federal
6	Racing Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Summary of Work

Mentioned facility has failed 3 year overfill protection testing. Owner wants to install all new overfill protection droptubes and remove old ball floats valves. Scope of work will be as follow

1. Removing of old straight droptubes.
2. Installation of new EMCO Overfill prevention droptubes set at or less than 95% of the tank capacity as instructed by manufacturer.
3. Removal of old ball float vent valves with OPW ball vent cage extractor tool.
4. Will provide set point calculatio sheet for tanks as per tank chart.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
American Petroleum Solutions LLC 180 Forest Trail Oak Brook, IL 60523	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/16/2024

Sincerely,



Daniel Starks