



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 2036692
Permit #: 00857-2023UPG
Request Rec'd: 08/04/2023
Amended Date: 09/21/2023 DS
Approval Date: 08/06/2023 DS
Permit Expires: 02/06/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sangha Petroleum, Inc. 12301 S. Archer Ave. Lemont, IL 60439 Cook County Contact: Roy Sangha 630/215-9103	FACILITY - name and address where tanks are located: Sangha Petroleum, Inc. 12301 South Archer Avenue Lemont, IL 60439 Cook County Contact: Roy Sangha 630/215-9103
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Diesel Fuel	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	New

Summary of Work

Replacing diesel and premium single wall spill bucket with double wall spill bucket part number 1C-3112D and installing new drop tube

Special Contingencies

Amendment Reason:

T3 Diesel drop is also being replaced Also installed double wall bucket and drop tube on premiem

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Reliable Pump Service and Maintenance 14007 S Bell Road Suite 228 Homer Glen, IL 60491	Contact Person: John Baio, Jr. Phone: 815/546-7867 Email: Reliablepumpservice@yahoo.com Contractor License # IL002433 Exp. 10/7/2024

Sincerely,

Daniel G. Starks

Daniel Starks