



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 1005442  
Permit #: 01100-2023UPG  
Request Rec'd: 09/25/2023  
Approval Date: 09/25/2023 DS  
Permit Expires: 03/26/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                                     |                                                                                                                                                                                                       |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Woodhaven Association<br>P.O. Box 110 509 Lamoille Road<br>Sublette, IL 61367<br>Lee County<br>Contact: Reece Howell 815/849-5107 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Woody's True Value<br>1802 Sublette (Lamoille & Tower Rd)<br>Sublette, IL 61367<br>Lee County<br>Contact: Scott Hanson 815/849-5107 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Tanks on the Permit For Piping Only**

| Tank # | Product     | Capacity | Tank Status      | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 5      | Diesel Fuel | 5,000    | Currently in use | Federal          |

**Tank 5 Equipment**

| Equipment Type                | Permit Equipment                                                   | Action                                                                        |
|-------------------------------|--------------------------------------------------------------------|-------------------------------------------------------------------------------|
| Piping                        | Flexible Double Wall A.P.T. Poly Tech P175SC                       | Replacing - Piping - Fiberglass Double Wall                                   |
| Leak Detection - Piping       | Electronic Pressurized Line Leak Detection                         | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Spill Containment Device      | Double Wall Spill Bucket                                           | Replacing - Spill Contain Device - Single Wall Spill Bucket                   |
| Corrosion Protection - Piping | Flexible Non-Corrosive                                             | Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive                |
| Corrosion Protection - Piping | Isolation Boots Flex Connector                                     | Removing                                                                      |
| Corrosion Protection - Piping | Sacrificial Anode Cathodic Protection                              | Removing                                                                      |
| Leak Detection - Piping       | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | New                                                                           |

**Summary of Work**

Replace existing diesel line with new flexible APT piping, add sensor to the diesel STP sump and add ELLD to the diesel line.

**Special Contingencies**

Replaced piping exceeds 20 feet or 50% of the total pipe run.


**NOTE: Dispensers must maintain a full 10' to buildings and property lines.**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Glen Davis  
Phone: 563/340-5216  
Email: gdavis@senecaco.com  
Contractor License # IL598 Exp. 2/23/2024

Sincerely,



---

Daniel Starks