



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 6013612  
Permit #: 01106-2023UPG  
Request Rec'd: 09/26/2023  
Approval Date: 09/26/2023 DS  
Permit Expires: 03/26/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Gateway FS, Inc. P.O. Box 100 Red Bud, IL 62278 Randolph County Contact: Greg Birchler 618/282-3454	<b>FACILITY</b> - name and address where tanks are located: Gateway FS 9951 State Rt. 127 Nashville, IL 62263 Washington County Contact: Brad Maschhoff 618/713-4180
---	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	B-11	10,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	Replacing - Piping - Fiberglass Single Wall Piping

**Dispensers on the Permit**

Dispenser	Action
3/4	Sump / Sensors Changing

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Summary of Work**

The sear valve under dispenser 3/4 is bad. We will sawcut the existing island form, install new sump, flex connector and shear valve.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/267-1231 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks

**For Office Use Only**

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing