



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2009067
Permit #: 01117-2023UPG
Request Rec'd: 09/27/2023
Approval Date: 09/28/2023 DS
Permit Expires: 03/28/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sibi Kadalimattom 1701 W Harrison Maywood, IL 60153 Cook County Contact: Sibi or Manoj Kadalimattom 708/343-8705	FACILITY - name and address where tanks are located: Maywood Mart Care 1701 W. Harrison Maywood, IL 60153 Cook County Contact: Sibi or Manoj Kadalimattom 708/343-8705
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

Summary of Work

Installing overfill drop tubes on Regular and Premium and Double Wall Spill Bucket on Regular.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 1058 National Parkway Schaumburg, IL 601734519	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2025

Sincerely,

Daniel Starks