



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2016452
Permit #: 01118-2023UPG
Request Rec'd: 09/27/2023
Approval Date: 09/28/2023
Permit Expires: 03/28/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Norman Junejo 7700 S. Kedzie Chicago, IL 60652 Cook County Contact: NomanJunejo 312/731-4896 | FACILITY - name and address where tanks are located: 7700 Kedzie Gas Corp. 7700 S. Kedzie Chicago, IL 60652 Cook County Contact: 312/731-4896 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 6 | Gasoline - Premium | 8,000 | Currently in use | Federal |
| 7 | Gasoline - Regular | 12,000 | Currently in use | Federal |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor | Reusing Existing |

Summary of Work

The containmnet entry boots are damaged beyond repair so reeplacing containments on both tanks to prevent water ingress

Special Contingencies

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504 | Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025 |

Sincerely,

Seán Keane

Raul Valdivia