



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2032853  
Permit #: 00989-2023UPG  
Request Rec'd: 09/01/2023  
Amended Date: 09/30/2023 DS  
Approval Date: 09/02/2023 DS  
Permit Expires: 03/04/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Express Group, LLC 101 West Madison Maywood, IL 60153 Cook County Contact: Amin Ibrahim 708/343-3231	<b>FACILITY</b> - name and address where tanks are located: Mobil 101 West Madison Avenue Maywood, IL 60153 Cook County Contact: Hatem Nofal 708/343-3231
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	8,000	Currently in use	Federal
3	Gasoline - Regular	6,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
11/12	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Dispenser 11/12 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Summary of Work**

Removing dispenser 11 and 12, installing new single wall sump and replacing part of the product line, then reinstalling dispenser after passing test

**Special Contingencies****Amendment Reason:**

Installing containment under dispenser 1-2 and manifolding regular lines at pump1-2

**NOTE:** Manifold of piping under a dispenser shall not be done above a shear valve.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Reliable Pump Service and Maintenance  
14007 S Bell Road Suite 228  
Homer Glen, IL 60491

Contact Person: John Baio, Jr.  
Phone: 815/546-7867  
Email: Reliablepumpservice@yahoo.com  
Contractor License # IL002433 Exp. 10/7/2024

Sincerely,



Daniel Starks

**For Office Use Only****Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

**Dispenser 11/12 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing