

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

## FOR OFFICE USE ONLY

Facility #: 5037309
Permit #: 01123-2023UPG
Request Rec'd: 09/29/2023
Approval Date:09/30/2023 DS
Permit Expires: 04/01/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

#### OWNER OF TANKS

- Corporation, partnership, or other business entity:

Madras Real Estate, LLC 2130 Kienlen Avenue St. Louis, MO 63121 (None) County

Contact: Mike Madras 314/383-3700

### **FACILITY**

- name and address where tanks are located:

Wally Hutter Oil Company d/b/a Pac Pride / Energy

Petroleum Co.

3025 Wisemann Lane Quincy, IL 62301

Adams County

Contact: Michael Madras 314/383-3700

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	12,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal
3	Gasoline - Premium	4,000	Currently in use	Federal

## Tank 1 Equipment

Equipment Permit Equipment		Action	
	, , , , , , , , , , , , , , , , , , , ,	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1000 with SCALD	

## **Tank 2 Equipment**

Equipment Permit Equipment		Action	
	, , , , , , , , , , , , , , , , , , , ,	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1000 with SCALD	

## **Tank 3 Equipment**

Equipment Type	Permit Equipment	Action	
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 400	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1000 with SCALD	

## **Summary of Work**

REMOVING THE INCON TS1001 WITH SCALD AND INASTALL A EVO 400 WITH SCALD

#### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:

R. L. Hoener Company

2923 Gardner Expressway P. O. Box 1086

Quincy, IL 62305

Contact Person: Marty Jackson Phone: 217/223-2190

Phone: 21//223-2190 Email: marty@rlhoener.com

Contractor License # IL2021 Exp. 5/22/2024

Sincerely, Daniel J. Starks

Daniel Starks