



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2001747
Permit #:	01130-2023UPG
Request Rec'd:	10/02/2023
Approval Date:	10/02/2023 DS
Permit Expires:	04/02/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Allied Waste Services 5050 West Lake Street Melrose Park, IL 60160 Cook County Contact: Bob Habbe 708/345-3055Ext.2186	FACILITY - name and address where tanks are located: Allied Waste Services 4800 West Lake Street Melrose Park, IL 60160 Cook County Contact: Tracy Smith 708/345-3055Ext.2186
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	10,000	Currently in use	Federal
5	Diesel Fuel	10,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c

Summary of Work

Beacon is replacing the existing ATG (TLS 300c) with a Veeder Root TLS 350. We are also relocating the ATG from the office to the Scale House where the STP wiring is located. We are adding Positive Shutdown the the STP on Tank 4 to resolve an NOV issue.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2025

Sincerely,

Daniel Starks